


ADLATUS APPS

Product brochure · EN, Edition 04.24





Docuthe Find technical documents. TechLiPedia TechLiPedia Technical Information and operating instructions in HTML format for smartphones, tablets and computers PartDetective Find spare parts for Kromschröder products. Product finder (ProFi) Find Kromschröder products. Nominal size DN Determine the nominal size DN for Kromschröder products. Product-related apps Selector Product selection help for BCU 4 and ECOMAX Burner flow rate curve Draw burner flow rate curves for ThermJet TJ Draw burner flow rate curves for ThermJet TJ Calculating the cooling air Calculate the cooling air in order to prevent overheating of switched off Kromschröder puries. Burner length of the BIC/ZIC in the case of horizontal installation Draw burner flow rate curves for ThermJet TJ Calculate the steel extension in order to adapt BIC burners to different furnace wall thicknesses. Burner length of the BIC/ZIC in the case of installation Calculate the steel extension in order to adapt BIC burners to different furnace wall thicknesses. Burner length of the BIC/ZIC in the case of installation Calculate the steel extension for BIC burners which are fitted at an angle. BIO/ZIO burner length in burner block Calculate the steel extension for BIC burners which are fitted at an angle. BIO/ZIO burner length in burner block Calculate the steel extension for BIC burners which are fitted at an angle. Calculate the steel extension for BIC burner using the type code. Flame tube FPT Determine the dimensions of the flame tube FPT for a BIO/ZIO burner. Calculate the minimum low-fire rate of a Kromschröder burner. Calculate the measurement time tube FPT for a BIO/ZIO burner. Calculate the leakage rate of the ceramic radiant tube SER-C. Calculate the measurement time of tightness controls TC 1, TC 2, TC 3 TC 1, TC 2, TC 3 TC 1, TC 2, TC 3 TE opening pressure of the safety relief valve (SRV) and trip pressures for the shut-off valve (SRV) and trip pressures for the shut-off valve (SRV) and trip pressure	Арр	Purpose
Technical Information and operating instructions in HTML format for smartphones, tablets and computers Find spare parts for Kromschröder products. Product finder (ProFi) Find Kromschröder products. Nominal size DN Product-related apps Selector Product flow rate curve Draw burner flow rate curves Therm Jet TJ Draw burner flow rate curves for Therm Jet TJ. Calculating the cooling air of which the BIC/ZIC in the case of horizontal an angle Burner length of the BIC/ZIC in the case of installation and an angle Burner length of the BIC/ZIC in the case of installation and an angle flow the BIC/ZIC in the case of installation and the steel extension for BIC burners which are flow the BIC/ZIC in the case of installation and the steel extension for BIC burners which are flow the BIC/ZIC burner and angle flow the BIC/ZIC burner and the BIC/ZIC bur		•
HTML format for smartphones, tablets and computers PartDetective Find spare parts for Kromschröder products. Product finder (ProFi) Find Kromschröder products. Product Finder (Romschröder products. Product-related apps Selector Product selection help for BCU 4 and ECOMAX Burner flow rate curve Draw burner flow rate curves. ThermJet TJ Draw burner flow rate curves of which selecting the cooling air in order to prevent overheating of switched off Kromschröder burners. Burner length of the BIC/ZIC in the case of horizontal installation burner sto different furnace wall thicknesses. Burner length of the BIC/ZIC in the case of installation at an angle. BIO/ZIO burner length in burner block Calculate the steel extension in order to adapt BIC burners to different furnace wall thicknesses. Burner length of the BIC/ZIC in the case of installation at an angle. Calculate the burner length of BIO/ZIO burner using the type code. Calculate the burner length of a BIO/ZIO burner using the type code. Determine the dimensions of the flame tube FPT for a BIO/ZIO burner. Calculating the minimum low-fire rate Calculate the minimum low-fire rate of a Kromschröder burner. Calculating the minimum low-fire rate Calculate the leakage rate of the ceramic radiant tube SER-C. Safety time on start-up Calculating measurement time t _M of tightness controls TC 1, TC 2, TC 3 Calculating test period t _P of tightness control TC 4 Calculating test period t _P of tightness control TC 4 Calculating test period t _P of tightness control TC 4 Calculating test period t _P of tightness control TC 4 Calculating the measurement time of tightness control TC 4 for adaptation to different inlet pressures, test volumes and leakage rates. The opening pressure of the safety relief valve (SRV) and trip pressure for the shut-off valve (SSV) are calculated on the basis of the outlet pressure set on the pressure regulator (GPR). Chowerting units Converting units for pressure, capacity, temperature, etc. Determining the combustion values Determining	Docuthek	Find technical documents.
Product finder (ProFi) Find Kromschröder products. Nominal size DN Determine the nominal size DN for Kromschröder products. Product-related apps Selector Product selection help for BCU 4 and ECOMAX Burner flow rate curve Draw burner flow rate curves. Therm Jet TJ Draw burner flow rate curves for Therm Jet TJ. Calculating the cooling air Calculating the cooling air in order to prevent overheating of switched off Kromschröder burners. Burner length of the BIC/ZIC in the case of horizontal installation burner should burner should be the steel extension in order to adapt BIC burners to different furnace wall thicknesses. Burner length of the BIC/ZIC in the case of installation at an angle. BlO/ZIO burner length in burner block Calculate the steel extension for BIC burners which are fitted at an angle. BlO/ZIO burner length in burner block Calculate the between the dimensions of the flame tube FPT for a BIO/ZIO burner. Calculate the burner length of a BIO/ZIO burner using the type code. Determine the dimensions of the flame tube FPT for a BIO/ZIO burner. Calculating the minimum low-fire rate Calculate the minimum low-fire rate of a Kromschröder burner. Calculate the minimum low-fire rate of a Kromschröder burner. Calculate the minimum low-fire rate of a Kromschröder burner. Calculate the measurement time of tightness controls TC 1, TC 2, TC 3 Calculate the measurement time of tightness controls TC 1, TC 2, TC 3 Calculate the measurement time of tightness controls TC 4 to adaptation to different inlet pressures, test volumes and leakage rates. Calculate the test period of tightness control TC 4 for adaptation to different inlet pressures, test volumes and leakage rates. Calculate the test period of tightness control TC 4 for adaptation to different inlet pressures, test volumes and leakage rates. Calculate the test period of tightness control TC 4 for adaptation to different inlet pressures, test volumes and leakage rates. Calculate the test period of tightness control TC 4 for adaptation to dif	TechLiPedia	
Product-related apps Selector	PartDetective	Find spare parts for Kromschröder products.
Product-related apps Selector Burner flow rate curve Draw burner flow rate curves. Therm Jet TJ Calculating the cooling air Burner length of the BIC/ZIC in the case of horizontal installation Burner length of the BIC/ZIC in the case of installation at an an angle Bion ZIO burner length in burner block Flame tube FPT Calculating the minimum low-fire rate Berner length of the BIC/ZIC in the case of installation at an angle. Bion ZIO burner length in burner block Calculate the burner length of a Bion ZIO burner which are fitted at an angle. Bion ZIO burner length in burner block Calculate the burner length of a Bion ZIO burner using the type code. Flame tube FPT Determine the dimensions of the flame tube FPT for a Bion ZIO burner. Calculate the burner length of a Bion ZIO burner using the type code. SER-C leakage rate Calculate the minimum low-fire rate of a Kromschröder burner. Safety time on start-up Calculating measurement time t _M of tightness controls TC 1, TC 2, TC 3 Calculating measurement time t _M of tightness controls TC 1, TC 2, TC 3 Calculating test period t _P of tightness control TC 4 Pressure levels for setting GPR, SRV and SSV Calculate the test period of tightness control TC 4 for adaptation to different inlet pressures, test volumes and leakage rates. The opening pressure of the safety relief valve (SRV) and trip pressures for the outlet pressure set on the pressure regulator (GPR). Global apps FuelManager Determining the gas key data and calculating the gas mixture of two gases Convert general units for pressure, capacity, temperature, etc. Determining the orifices Determiner the composition and combustion properties of gas types. Determining the required SIL, PL Determining the required SIL, PL Determining the risk, determine SIL pursuant to IEC 62061 and PL pursuant to ISO 13849-1.	Product finder (ProFi)	Find Kromschröder products.
Selector Burner flow rate curve Draw burner flow rate curves. Therm Jet TJ Calculating the cooling air Calculating the cooling air Calculating the cooling air Calculating the cooling air Calculate the cooling air in order to prevent overheating of switched off Kromschröder burners. Burner length of the BIC/ZIC in the case of horizontal installation Burner length of the BIC/ZIC in the case of installation at an angle BIO/ZIO burner length in burner block Calculate the steel extension in order to adapt BIC burners to different furnace wall thicknesses. Burner length in burner block Calculate the burner length of a BIO/ZIO burner using the type code. Flame tube FPT Determine the dimensions of the flame tube FPT for a BIO/ZIO burner. Calculate the minimum low-fire rate of a Kromschröder burner. Calculating the minimum low-fire rate Calculate the minimum low-fire rate of a Kromschröder burner. Calculating measurement time t _M of tightness controls TC 1, TC 2, TC 3 Calculating measurement time t _M of tightness controls TC 1, TC 2, TC 3 Calculating test period t _P of tightness control TC 4 Calculating test period t _P of tightness control TC 4 Calculating test period t _P of tightness control TC 4 Calculating test period t _P of tightness control TC 4 Calculating test period t _P of tightness control TC 4 Calculate the steet period of tightness control TC 4 for adaptation to different inlet pressures, test volumes and leakage rates. Calculate the steet period of tightness control TC 4 for adaptation to different inlet pressures, test volumes and leakage rates. Calculate the steet period of tightness control TC 4 for adaptation to different inlet pressures, test volumes and leakage rates. Calculate the steet spread of tightness control TC 4 for adaptation to different inlet pressures, test volumes and leakage rates. Calculate the test period of tightness control TC 4 for adaptation to different inlet pressures, test volumes and leakage rates. Calculate the test period of tightness control TC 4 for adaptation to	Nominal size DN	
Burner flow rate curve Therm Jet TJ Draw burner flow rate curves. Therm Jet TJ Draw burner flow rate curves for Therm Jet TJ. Calculating the cooling air Calculating the cooling air Calculate the cooling air in order to prevent overheating of switched off Kromschröder burners. Burner length of the BIC/ZIC in the case of horizontal installation Burner length of the BIC/ZIC in the case of installation an angle Calculate the steel extension in order to adapt BIC burners to different furnace wall thicknesses. Burner length of the BIC/ZIC in the case of installation an angle Calculate the steel extension for BIC burners which are fitted at an angle. Calculate the burner length of a BIO/ZIO burner using the type code. Determine the dimensions of the flame tube FPT for a BIO/ZIO burner. Calculate the minimum low-fire rate of a Kromschröder burner. Calculate the minimum low-fire rate of a Kromschröder burner. SER-C leakage rate Calculate the leakage rate of the ceramic radiant tube SER-C. Safety time on start-up Calculate the measurement time of tightness controls TC 1, TC 2, TC 3 Calculate the measurement time of tightness controls TC 1, TC 2, TC 3 Calculate the measurement time of tightness controls TC 1 a for adaptation to different inlet pressures, test volumes and leakage rates. Calculate the test period of tightness control TC 4 Pressure levels for setting GPR, SRV and SSV Calculate the test period of tightness control TC 4 for adaptation to different inlet pressures, test volumes and leakage rates. The opening pressure of the safety relief valve (SRV) and trip pressures for the shut-off valve (SSV) are calculated on the basis of the outlet pressure set on the pressure regulator (GPR). Clobal apps FuelManager Converting units Determining the gas key data and calculating the gas mixture of two gases mixture of two gases Converting emissions. Enter the emissions measured in ppm or mg/m³, the measured O₂ value and the O₂ reference value. Then read off the converted values. Depending on the risk, deter	Product-related apps	
ThermJet TJ Calculating the cooling air Calculating the cooling air Calculate the cooling air in order to prevent overheating of switched off Kromschröder burners. Burner length of the BIC/ZIC in the case of horizontal installation Calculate the steel extension in order to adapt BIC burners to different furnace wall thicknesses. Burner length of the BIC/ZIC in the case of installation at an angle BIO/ZIO burner length in burner block Calculate the steel extension for BIC burners which are fitted at an angle. Calculate the burner length of a BIO/ZIO burner using the type code. Calculate the burner length of a BIO/ZIO burner using the type code. Calculate the minimum low-fire rate burner. Calculating the minimum low-fire rate Calculate the minimum low-fire rate of a Kromschröder burner. Calculate the leakage rate of the ceramic radiant tube SER-C. Safety time on start-up Calculating measurement time t _M of tightness controls TC 1, TC 2, TC 3 Calculate the measurement time of tightness controls TC 1, TC 2, TC 3 Calculate the teakage rates. Calculate the test period of fifthers control TC 4 for adaptation to different inlet pressures, test volumes and leakage rates. Calculate the test period of tightness control TC 4 for adaptation to different inlet pressures, test volumes and leakage rates. Calculate the test period of tightness control TC 4 for adaptation to different inlet pressures set on the pressure regulator (GPR). FluelManager Determining the gas key data and calculating the gas mixture of two gases Converting units Determining the orifices Determine restricting and measuring orifices. Calculating the combustion values Determine the composition and combustion properties of gas types. Converting emissions. Enter the emissions measured in ppm or mg/m³, the measured O₂ value and the O₂ reference value. Then read off the converted values. Depending on the risk, determine SIL pursuant to IEC 62061 and PL pursuant to ISC 13849-1.	Selector	Product selection help for BCU 4 and ECOMAX
Calculating the cooling air Calculating the cooling air of whiched off Kromschröder burners. Burner length of the BIC/ZIC in the case of horizontal installation Burner length of the BIC/ZIC in the case of installation at an angle Burner length of the BIC/ZIC in the case of installation at an angle BIO/ZIO burner length in burner block Calculate the steel extension for BIC burners which are fitted at an angle. BIO/ZIO burner length in burner block Calculate the burner length of a BIO/ZIO burner using the type code. Determine the dimensions of the flame tube FPT for a BIO/ZIO burner. Calculate the minimum low-fire rate of a Kromschröder burner. SER-C leakage rate Calculate the leakage rate of the ceramic radiant tube SER-C. Safety time on start-up Calculating measurement time t _M of tightness controls TC 1, TC 2, TC 3 Calculate the measurement time of tightness controls TC 1, TC 2, TC 3 Calculating test period t _P of tightness control TC 4 Pressure levels for setting GPR, SRV and SSV Calculate the test period of tightness control TC 4 for daptation to different inlet pressures, test volumes and leakage rates. The opening pressure of the safety relief valve (SRV) and trip pressures for the shut-off valve (SSV) are calculated on the basis of the outlet pressure set on the pressure regulator (GPR). Global apps FuelManager Determining the gas key data and calculating the gas mixture of two gases Converting units Determine restricting and measuring orifices. Determine the composition and combustion properties of gas types. Converting emissions. Enter the emissions measured in ppm or mg/m³, the measured O ₂ value and the O ₂ reference value. Then read off the converted values. Determining the required SIL, PL Determining the risk, determine SIL pursuant to IEC 62061 and PL pursuant to ISC 13849-1.	Burner flow rate curve	Draw burner flow rate curves.
Burner length of the BIC/ZIC in the case of horizontal installation Burner length of the BIC/ZIC in the case of horizontal installation at an angle BIO/ZIO burner length in burner block BIO/ZIO burner length in burner block Calculate the steel extension in order to adapt BIC burners to different furnace wall thicknesses. Burner length of the BIC/ZIC in the case of installation at an angle. Calculate the burner length of a BIO/ZIO burner using the type code. Calculate the burner length of a BIO/ZIO burner using the type code. Determine the dimensions of the flame tube FPT for a BIO/ZIO burner. Calculating the minimum low-fire rate Calculate the minimum low-fire rate of a Kromschröder burner. Calculate the minimum low-fire rate of a Kromschröder burner. SER-C leakage rate SER-C leakage rate Calculate the leakage rate of the ceramic radiant tube SER-C. Safety time on start-up Calculating measurement time t _M of tightness controls TC 1, TC 2, TC 3 Calculate the measurement time of tightness controls TC 1, TC 2, TC 3 Calculate the temperature time of tightness controls TC 4 for adaptation to different inlet pressures, test volumes and leakage rates. Calculate the test period of tightness control TC 4 for adaptation to different inlet pressures, test volumes and leakage rates. The opening pressure of the safety relief valve (SRV) and trip pressures for the shut-off valve (SSV) are calculated on the basis of the outlet pressure set on the pressure regulator (GPR). Global apps FuelManager Determining the gas key data and calculating the gas mixture of two gases Converting units Converting units for pressure, capacity, temperature, etc. Determine the composition and combustion properties of gas types. Converting emissions. Enter the emissions measured in ppm or mg/m³, the measured O ₂ value and the O ₂ reference value. Then read off the converted values.	ThermJet TJ	Draw burner flow rate curves for ThermJet TJ.
burners to different furnace wall thicknesses. Burner length of the BIC/ZIC in the case of installation at an angle BIO/ZIO burner length in burner block Calculate the steel extension for BIC burners which are fitted at an angle. Calculate the burner length of a BIO/ZIO burner using the type code. Flame tube FPT Determine the dimensions of the flame tube FPT for a BIO/ZIO burner. Calculating the minimum low-fire rate Calculate the leakage rate of the ceramic radiant tube SER-C. Calculate the leakage rate of the ceramic radiant tube SER-C. Safety time on start-up Calculating measurement time t _M of tightness controls TC 1, TC 2, TC 3 Calculating measurement time t _M of tightness controls TC 1, TC 2, TC 3 Calculating test period t _P of tightness control TC 4 Pressure levels for setting GPR, SRV and SSV The opening pressure of the safety relief valve (SRV) and trip pressures for the shut-off valve (SSV) are calculated on the basis of the outlet pressure set on the pressure regulator (GPR). Global apps FuelManager Determining the gas key data and calculating the gas mixture of two gases Converting units Determining the orifices Determine the dimensions of the flame tube FPT for a BIO/ZIO burner. Calculate the leakage rate of the ceramic radiant tube SER-C. Calculate the leakage rate of the ceramic radiant tube SER-C. Calculate the measurement time of tightness controls TC 1-3 for adaptation to different inlet pressures, test volumes and leakage rates. The opening pressure of the safety relief valve (SRV) and trip pressures for the shut-off valve (SSV) are calculated on the basis of the outlet pressure set on the pressure regulator (GPR). Global apps Converting units Determining the gas key data and calculating the gas mixture of two gases Converting emissions. Enter the emissions measured in ppm or mg/m³, the measured O ₂ value and the O ₂ reference value. Then read off the converted values. Determining the required SIL, PL Determining the required SIL, PL Determining the requir	Calculating the cooling air	
an angle BIO/ZIO burner length in burner block Calculate the burner length of a BIO/ZIO burner using the type code. Flame tube FPT Determine the dimensions of the flame tube FPT for a BIO/ZIO burner. Calculating the minimum low-fire rate Calculate the minimum low-fire rate of a Kromschröder burner. SER-C leakage rate SER-C. Safety time on start-up Calculate the leakage rate of the ceramic radiant tube SER-C. Safety time on start-up Calculating measurement time t _M of tightness controls TC 1, TC 2, TC 3 Calculating measurement time t _M of tightness controls TC 1, TC 2, TC 3 Calculating test period t _P of tightness control TC 4 Calculating test period t _P of tightness control TC 4 Pressure levels for setting GPR, SRV and SSV The opening pressure of the safety relief valve (SRV) and trip pressures for the shut-off valve (SSV) are calculated on the basis of the outlet pressure set on the pressure regulator (GPR). Global apps FuelManager Determining the gas key data and calculating the gas mixture of two gases Converting units Determining the orifices Determine restricting and measuring orifices. Determine the composition and combustion properties of gas types. Calculating the required SIL, PL Determining the required SIL pursuant to IEC 62061 and PL pursuant to ISO 13849-1.	· · · · · · · · · · · · · · · · · · ·	·
Flame tube FPT Determine the dimensions of the flame tube FPT for a BIO/ZIO burner. Calculating the minimum low-fire rate Calculate the minimum low-fire rate of a Kromschröder burner. SER-C leakage rate SER-C. Safety time on start-up Calculating measurement time t _M of tightness controls TC 1, TC 2, TC 3 Calculating measurement time t _M of tightness controls TC 1, TC 2, TC 3 Calculating test period t _P of tightness control to the basis of the outlet pressures, test volumes and leakage rates. Calculate the test period of tightness control TC 4 for adaptation to different inlet pressures, test volumes and leakage rates. The opening pressure of the safety relief valve (SRV) and trip pressures for the shut-off valve (SSV) are calculated on the basis of the outlet pressure set on the pressure regulator (GPR). Global apps FuelManager Determining the gas key data and calculating the gas mixture of two gases mixture of two gases Converting units Determining the orifices Determine restricting and measuring orifices. Determine the composition and combustion properties of gas types. Converting emissions. Enter the emissions measured in ppm or mg/m³, the measured O ₂ value and the O ₂ reference value. Then read off the converted values. Depending on the risk, determine SIL pursuant to IEC 62061 and PL pursuant to ISO 13849-1.		
Flame tube FPT BIO/ZIO burner. Calculating the minimum low-fire rate Calculate the minimum low-fire rate of a Kromschröder burner. SER-C leakage rate SER-C. Safety time on start-up Calculate the measurement time of tightness controls TC 1, TC 2, TC 3 Calculating measurement time t _M of tightness controls TC 1, TC 2, TC 3 Calculate the measurement time of tightness controls TC 1 and adaptation to different inlet pressures, test volumes and leakage rates. Calculate the test period of tightness control TC 4 Calculate the test period of tightness control TC 4 for adaptation to different inlet pressures, test volumes and leakage rates. Calculate the test period of tightness control TC 4 for adaptation to different inlet pressures, test volumes and leakage rates. The opening pressure of the safety relief valve (SRV) and trip pressures for the shut-off valve (SSV) are calculated on the basis of the outlet pressure set on the pressure regulator (GPR). Global apps FuelManager Determining the gas key data and calculating the gas mixture of two gases Converting units Convert general units for pressure, capacity, temperature, etc. Determine the composition and combustion properties of gas types. Calculating the combustion values Determine the composition and combustion properties of gas types. Converting emissions. Enter the emissions measured in ppm or mg/m³, the measured O₂ value and the O₂ reference value. Then read off the converted values. Depending on the risk, determine SIL pursuant to IEC 62061 and PL pursua	BIO/ZIO burner length in burner block	
Calculating the minimum low-fire rate SER-C leakage rate SER-C. Safety time on start-up Calculate the leakage rate of the ceramic radiant tube SER-C. Safety time on start-up Calculating measurement time t _M of tightness controls TC 1, TC 2, TC 3 Calculate the measurement time of tightness controls TC 1 – 3 for adaptation to different inlet pressures, test volumes and leakage rates. Calculate the test period of tightness control TC 4 for adaptation to different inlet pressures, test volumes and leakage rates. The opening pressure of the safety relief valve (SRV) and trip pressures for the shut-off valve (SSV) are calculated on the basis of the outlet pressure set on the pressure regulator (GPR). Global apps FuelManager Determining the gas key data and calculating the gas mixture of two gases Converting units Convert general units for pressure, capacity, temperature, etc. Determine restricting and measuring orifices. Calculating the combustion values Determine the composition and combustion properties of gas types. Converting emissions. Enter the emissions measured in ppm or mg/m³, the measured O₂ value and the O₂ reference value. Then read off the converted values. Determining the required SIL, PL Depending on the risk, determine SIL pursuant to IEC 62061 and PL pursuant to ISO 13849-1.	Flame tube FPT	
SER-C. Safety time on start-up t _{SA} pursuant to EN 746-2:2010 Calculating measurement time t _M of tightness controls TC 1, TC 2, TC 3 Calculating test period t _P of tightness control TC 4 Calculating test period t _P of tightness control TC 4 Calculating test period t _P of tightness control TC 4 Pressure levels for setting GPR, SRV and SSV The opening pressure of the safety relief valve (SRV) and trip pressures for the shut-off valve (SSV) are calculated on the basis of the outlet pressure set on the pressure regulator (GPR). Global apps FuelManager Determining the gas key data and calculating the gas mixture of two gases Converting units Converting units for pressure, capacity, temperature, etc. Determine the combustion values Determine the composition and combustion properties of gas types. Converting emissions. Enter the emissions measured in ppm or mg/m³, the measured O ₂ value and the O ₂ reference value. Then read off the converted values. Determining the required SIL, PL Depending on the risk, determine SIL pursuant to IEC 62061 and PL pursuant to ISO 13849-1.	Calculating the minimum low-fire rate	
Calculate the measurement time of tightness controls TC 1, TC 2, TC 3 Calculate the measurement time of tightness controls TC 1, TC 2, TC 3 Calculating test period tp of tightness control TC 4 Calculating test period tp of tightness control TC 4 Calculate the test period of tightness control TC 4 for adaptation to different inlet pressures, test volumes and leakage rates. The opening pressure of the safety relief valve (SRV) and trip pressures for the shut-off valve (SSV) are calculated on the basis of the outlet pressure set on the pressure regulator (GPR). Global apps FuelManager Determining the gas key data and calculating the gas mixture of two gases Converting units Converting units to open and measuring orifices. Determining the orifices Determine restricting and measuring orifices. Determine the composition and combustion properties of gas types. Converting emissions. Enter the emissions measured in ppm or mg/m³, the measured O2 value and the O2 reference value. Then read off the converted values. Determining the required SIL, PL Depending on the risk, determine SIL pursuant to IEC 62061 and PL pursuant to ISO 13849-1.	SER-C leakage rate	
Calculating measurement time t _M of tightness controls TC 1, TC 2, TC 3 TC 1, TC 2, TC 3 Calculating test period t _P of tightness control TC 4 Calculating test period t _P of tightness control TC 4 Calculate the test period of tightness control TC 4 for adaptation to different inlet pressures, test volumes and leakage rates. The opening pressure of the safety relief valve (SRV) and trip pressures for the shut-off valve (SSV) are calculated on the basis of the outlet pressure set on the pressure regulator (GPR). Global apps FuelManager Determining the gas key data and calculating the gas mixture of two gases Converting units Converting units Convert general units for pressure, capacity, temperature, etc. Determining the orifices Determine restricting and measuring orifices. Determine the composition and combustion properties of gas types. Converting emissions. Enter the emissions measured in ppm or mg/m³, the measured O ₂ value and the O ₂ reference value. Then read off the converted values. Determining the required SIL, PL Determining the risk, determine SIL pursuant to IEC 62061 and PL pursuant to ISO 13849-1.	Safety time on start-up	t _{SA} pursuant to EN 746-2:2010
Calculating test period tp of tightness control TC 4 adaptation to different inlet pressures, test volumes and leakage rates. The opening pressure of the safety relief valve (SRV) and trip pressures for the shut-off valve (SSV) are calculated on the basis of the outlet pressure set on the pressure regulator (GPR). Global apps FuelManager Determining the gas key data and calculating the gas mixture of two gases Converting units Converting units Convert general units for pressure, capacity, temperature, etc. Determining the combustion values Determine restricting and measuring orifices. Determine the composition and combustion properties of gas types. Converting emissions. Enter the emissions measured in ppm or mg/m³, the measured O₂ value and the O₂ reference value. Then read off the converted values. Determining the required SIL, PL Determining the risk, determine SIL pursuant to IEC 62061 and PL pursuant to ISO 13849-1.		TC 1 – 3 for adaptation to different inlet pressures, test
trip pressures for the shut-off valve (SSV) are calculated on the basis of the outlet pressure set on the pressure regulator (GPR). Global apps FuelManager Determining the gas key data and calculating the gas mixture of two gases Converting units Converting units Converting units or pressure, capacity, temperature, etc. Determining the orifices Determine restricting and measuring orifices. Determine the composition and combustion properties of gas types. Converting emissions. Enter the emissions measured in ppm or mg/m³, the measured 0₂ value and the 0₂ reference value. Then read off the converted values. Determining the required SIL, PL Determining the required SIL, PL Depending on the risk, determine SIL pursuant to IEC 62061 and PL pursuant to ISO 13849-1.	Calculating test period t _P of tightness control TC 4	adaptation to different inlet pressures, test volumes and
FuelManager Determining the gas key data and calculating the gas mixture of two gases Converting units Converting units Convert general units for pressure, capacity, temperature, etc. Determining the orifices Determine restricting and measuring orifices. Determine the composition and combustion properties of gas types. Converting emissions. Enter the emissions measured in ppm or mg/m³, the measured O₂ value and the O₂ reference value. Then read off the converted values. Determining the required SIL, PL Determining the required SIL, PL Determining the pas key data and calculating the gas mixture of two gases Converting emissions. Enter the emissions measured in ppm or mg/m³, the measured O₂ value and the O₂ reference value. Then read off the converted values. Determining the required SIL, PL	Pressure levels for setting GPR, SRV and SSV	trip pressures for the shut-off valve (SSV) are calculated on the basis of the outlet pressure set on the pressure
$\begin{tabular}{lllllllllllllllllllllllllllllllllll$	Global apps	
	FuelManager	
$ \begin{array}{c} \text{Calculating the combustion values} & \text{Determine the composition and combustion properties} \\ \text{of gas types.} \\ \text{Converting emissions. Enter the emissions measured in} \\ \text{ppm or mg/m}^3, \text{the measured } O_2 \text{ value and the } O_2 \\ \text{reference value. Then read off the converted values.} \\ \text{Determining the required SIL, PL} & \text{Depending on the risk, determine SIL pursuant to} \\ \text{IEC 62061 and PL pursuant to ISO 13849-1.} \\ \end{array} $	Converting units	1 , 1 ,
$\begin{array}{c} \text{Calculating the combustion values} & \text{of gas types.} \\ & \text{Converting emissions. Enter the emissions measured in} \\ \text{Emissions} & \text{ppm or mg/m}^3, \text{the measured O}_2 \text{ value and the O}_2 \\ \text{reference value. Then read off the converted values.} \\ \text{Determining the required SIL, PL} & \text{Depending on the risk, determine SIL pursuant to} \\ \text{IEC 62061 and PL pursuant to ISO 13849-1.} \\ \end{array}$	Determining the orifices	Determine restricting and measuring orifices.
$\begin{array}{ccc} \text{Emissions} & & \text{ppm or mg/m}^3, \text{the measured O}_2 \text{ value and the O}_2 \\ & \text{reference value. Then read off the converted values.} \\ \\ \text{Determining the required SIL, PL} & & \text{Depending on the risk, determine SIL pursuant to IEC 62061 and PL pursuant to ISO 13849-1.} \\ \end{array}$	Calculating the combustion values	
Determining the required SIL, PL IEC 62061 and PL pursuant to ISO 13849-1.	Emissions	ppm or mg/m 3 , the measured O_2 value and the O_2
${\rm CO_2Savings}$ ${\rm CalculatingCO_2savingswhenusinghydrogenH_2}$	Determining the required SIL, PL	, ,
	CO ₂ Savings	Calculating CO ₂ savings when using hydrogen H ₂

- Self-help tools
- App access via internet browser
- No installation required
- Usable with laptop, tablet or smartphone
- www.adlatus.org

APPLICATION

Helping you help yourself - these are the various ADLATUS apps.

They assist in the search for spare parts or complete products.

To calculate nominal diameters, burner flow curves, emissions, cooling air, etc.

All apps are available in German, English, French, Italian and Spanish.

They are linked to our technical documentation.

This way, whenever it is helpful, you have the right link to the right app right in front of you.

The most important apps can be marked as favorites.

You can access ADLATUS via your internet browser at www.adlatus.org



Elster GmbH Strotheweg 1 · 49504 Lotte (Büren) Germany Tel. +49 541 1214-0 hts.lotte@honeywell.com www.kromschroeder.com

