## 03251596




# Replacing power module LM 400 on burner control units BCU 460, 465 or 480


#### ! CAUTION

BCU 4xx/LM..E0 and BCU 4xx/LM..E1 have a different power supply for the gas valves. The following combinations are allowed:

- BCU 4xx..E1 + LM..E1 = power supply via L1,
- BCU 4xx..E0 + LM..E1 = power supply for gas valves via terminal 35, power supply for air outputs via L1,
- BCU 4xx..E0 + LM..E0 = power supply via terminal 35.
- LM 400 as a spare part: the identification numbers of the old and new unit must be identical. Identification number - see type label.



- 1 Disconnect the BCU from the electrical power supply.
- 2 Open the cover of the BCU.
- 3 Disconnect the connection plug from the power
- 4 Replace the module.



# Further information

More detailed information can be found in the electronic operating instructions BCU 46x, 480 using the following link:

https://docuthek.kromschroeder.com/documents/index.php?menuid=31&topmenu=31&lang=en&selclass=&sellang=&folder=401294



### Contact

# Honeywell



Flster GmbH Strotheweg 1, D-49504 Lotte (Büren) Tel. +49 541 1214-0 Fax +49 541 1214-370

We reserve the right to make technical modifications in the interests of progress.

If you have any technical questions, please contact your local branch office/agent. The addresses are

available on the Internet or from Elster GmbH.