



Number: UKCA/0558/22/055 Replaces: 17GR0210/00

Issue Date: 04-02-2022 Contract Number: PS7133

Due Date: 04-02-3032 Module: B (Type Testing)

Report Number: 119262 Scope: Gas Appliances

PIN: 0063BQ001/04 Page 1 of 2

UKCA TYPE EXAMINATION CERTIFICATE

Kiwa Ltd. hereby declares that the model type(s)

S11T

Manufactured by Elster GmbH (Honeywell)

Lotte - Büren, Germany

Meet(s) the essential requirements as described in the:

Gas Appliances Regulation (Regulation (EU) 2016/426 as brought into GB law and amended), and the Gas Appliances (Enforcement) and Miscellaneous Amendment Regulations 2018 No 389, and amendments to UK SI 2019/696 Product Safety and Metrology, and subsequent amendments, The Product Safety, Metrology and Mutual Recognition Agreement (Amendment) (EU Exit) Regulations 2019 No 1246, and subsequent amendments. This certificate is not valid in Northern Ireland – and is applicable to England, Scotland and Wales only.

Reference standards: BS EN 125:2010

Signed on behalf of Kiwa Ltd. (UK Approved Body Number 0558)

M 1 Contre

Mark Crowther Technical Director

Kiwa Ltd.

Kiwa Gastec

Malvern View Business Park Stella Way Bishops Cleeve Cheltenham GL52 7DQ

United Kingdom T +44 (0)1242 677877 F +44 (0)1242 676506

www.kiwa.co.uk





0217



Number: UKCA/0558/22/055 **Replaces:** 17GR0210/00

Issue Date: 04-02-2022 Contract Number: PS7133

Due Date: 04-02-2032 **Module:** B (Type Testing)

Report Number: 119262 Scope: Gas Appliances

PIN: 0063BQ001/04 **Page** 2 of 2

APPENDIX TO UKCA TYPE EXAMINATION CERTIFICATE

List of all available types:

Thermo-electric flame supervision devices approved on EN125

Class A

Mechanical strength Group 2

Max. ambient temperature -20°C / 60°C

TYPE NUMBER SURVEY:

S11T	Thermo-electric valve type S11T
15 20 25	Connection size DN 15 Connection size DN 20 Connection size DN 25
R	Screw connections acc. ISO 7-1
01 15	Maximum inlet pressure 100 mbar Maximum inlet pressure 1,5 bar
S	optional switch

Remark:

When the thermo-electrical valve is not provided with the optional switch, the letter 'S' is not listed in the type number survey