

EU type examination certificate**EU-Baumusterprüfbescheinigung****CERT****CE-0085AP0151**Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Elster GmbH Strotheweg 1, D-49504 Lotte (Büren)
Distributor <i>Vertreiber</i>	Elster GmbH Strotheweg 1, D-49504 Lotte (Büren)
Product Category <i>Produktart</i>	gas fittings: Relief device for natural gas and all-gas (4333)
Product Description <i>Produktbezeichnung</i>	Spring-loaded blow-off valve for reducing short-term pressure surges in regulation systems
Model <i>Modell</i>	VS BV...
Countries of Destination <i>Bestimmungsländer</i>	AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MT, NL, NO, PL, PT, RO, SE, SI, SK
Test Reports <i>Prüfberichte</i>	type testing: 16/198/4395/351 from 21.01.2017 (EBI)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN 33821 (01.03.2009)- partially

Validity / File no.
Gültigkeit / AZ

21.04.2018 until 19.02.2028 / 17-0123-GEA

22.02.2018 Kö A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EU Regulation

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EU-Verordnung EU/2016/426.

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Gas Category Gasart	Remarks Bemerkungen
fuel gases of the 1., 2. & 3. gas family	

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
VS BV 25 R 40 -4	connection: Rp 1 response pressure: 20...500 mbar accuracy group: AG 10 nominal diameter: DN 25 temperature range: -15 ... +60 °C max. allowable pressure PS: 4 bar	temperature range was deviating from DIN 33821 limited to -15 ° C

Hints of Utilization /Remarks Verwendungshinweise / Bemerkungen
Class B Body material: aluminum EN AC-47100 and EN AC-44200

NOT UP-TO-DATE
www.docuthek.com

DVGW