

# Certificate of Compliance

**Certificate:** 1251163 (LR 67684)

**Master Contract:** 175131

**Project:** 2038678

**Date Issued:** 2008/07/04

**Issued to:** Elster GmbH  
Postfach 2809  
Osnabrueck, 49018  
Germany  
Attention: Thomas Huning

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** JERRY TANG-KONG, C.E.T.

**Authorized by:** Calvin McKenzie, Product  
Group Manager



## PRODUCTS

**CLASS 2632 01** - FUEL BURNING EQUIPMENT (GAS) - Gas Burners, Electrical  
Equipment for Accessories

Ignition transformer, Model TZI, input rated 115V, 50/60Hz, output rated 7.5KV open circuit voltage, 20mA short circuit current (1 min. on, 2min. off intermittent operation).

Note: Above model is certified as a component of other certified equipment where the suitability of the combination is to be evaluated by CSA International.

## APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 13-1962 - Transformer for Luminous- Tube Signs, Oil or Gas-Burner Ignition