



| | | | |
|------------|--------------|-----------------|------------------------------|
| Number | 17GR0210/00 | Contract number | E001 |
| Issue date | 21-04-2018 | Scope | (EU) 2016/426 (9 March 2016) |
| Due date | 01-02-2028 | Module | B (Type testing) |
| PIN | 0063BQ001/04 | Report number | 119262 |

EU TYPE EXAMINATION CERTIFICATE (GAR)

Kiwa hereby declares that the flame supervision devices, type(s):

S11T

manufactured by

**Elster GmbH (Honeywell)
Lotte - Büren, Germany**

meet(s) the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

The compliance is based on examination to EN 125:2010.

The product(s) has/have been approved for all EU and EFTA countries.

A description of the specific types is given in the appendix to this certificate.

Luc Leroy, Kiwa



| | | | |
|------------|--------------|---------------|------------------------------|
| Number | 17GR0210/00 | Page | 1 of 1 |
| Issue date | 21-04-2018 | Scope | (EU) 2016/426 (9 March 2016) |
| Due date | 01-02-2028 | Module | B (Type testing) |
| PIN | 0063BQ001/04 | Report number | 119262 |

APPENDIX TO EU TYPE EXAMINATION CERTIFICATE (GAR)

List of all available types:

Thermo-electric flame supervision devices approved on EN125

Class A

Mechanical strength

Group 2

Max. ambient temperature

-20°C / 60°C

TYPE NUMBER SURVEY:

| | |
|------|---------------------------------|
| S11T | Thermo-electric valve type S11T |
| 15 | Connection size DN 15 |
| 20 | Connection size DN 20 |
| 25 | Connection size DN 25 |
| R | Screw connections acc. ISO 7-1 |
| 01 | Maximum inlet pressure 100 mbar |
| 15 | Maximum inlet pressure 1,5 bar |
| S | optional switch |

Remark: When the thermo-electrical valve is not provided with the optional switch, the letter 'S' is not listed in the type number survey