



Number	17GR0209/00	Contract number	E001
Issue date	21-04-2018	Scope	(EU) 2016/426 (9 March 2016)
Due date	01-02-2028	Module	B (Type testing)
PIN	0063BL1554	Report number	120909

EU TYPE EXAMINATION CERTIFICATE (GAR)

Kiwa hereby declares that the automatic shut-off valve, type(s):

VGP

manufactured by

**Elster GmbH (Honeywell)
Lotte - Büren, Germany**

meet(s) the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

The compliance is based on examination to EN 161:2011 + A3:2013.

The product(s) has/have been approved for all EU and EFTA countries.

A description of the specific types is given in the appendix to this certificate.

Luc Leroy, Kiwa



Number	17GR0209/00	Page	1 of 1
Issue date	21-04-2018	Scope	(EU) 2016/426 (9 March 2016)
Due date	01-02-2028	Module	B (Type testing)
PIN	0063BL1554	Report number	120909

APPENDIX TO EU TYPE EXAMINATION CERTIFICATE (GAR)

List of all available types: VGP

Electro-magnetic automatic shut-off valve approved on EN 161 Class A.

Degree of protection : IP 54
Ambient temperature range : -20 to +60 °C.
Mechanical strength : group 2

TYPE NUMBER SURVEY:

VGP 10...25	Connection size DN10, 25, 20 and 25
R	Screw connections acc. ISO 7
01	Max. inlet pressure 150 mbar
02	Max. inlet pressure 200 mbar
W	230V, 50/60 Hz
M	110V, 50/60 Hz
Q	120V, 50/60 Hz
5	Electrical connection Rectifier adapter without DIN plug (DIN43650, ISO4400)
6	Electrical connection Rectifier adapter with DIN plug (DIN43650, ISO4400)
6L	Electrical connection Rectifier adapter with DIN plug (DIN43650, ISO4400) with signal lamp
7	Electrical connection Device socket, 3-pin, with rectifier circuit
V	Viton valve disk seal
Z	Customer specified control

Special conditions:
None