



Certificate of Compliance

Certificate: 1251163

Master Contract: 175131

Project: 80062505

Date Issued: 2020-12-04

Issued To: Elster GmbH
Postfach 2809
Osnabrueck, Niedersachsen, 49018
Germany

Attention: Richard Twyrdy

The products listed below are eligible to bear the CSA Mark shown

Issued by: *Thao Cao*
Thao Cao



PRODUCTS

CLASS - C263201 - FUEL BURNING EQUIPMENT (GAS) Gas Burners, Electrical Equipment for Accessories

Ignition transformer Model TZI, input rated 115V, 50/60Hz, output rated 7.5kV open circuit voltage, 20mA short circuit current (1 min on, 2 min off intermittent operation).

Note: Above model is Certified as a component of other Certified equipment where the suitability of the combination is to be evaluated by CSA International

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 13-13 (reaffirmed 2018) - Transformers for oil- or gas-burner ignition equipment



Supplement to Certificate of Compliance

Certificate: 1251163

Master Contract: 175131

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

| Project | Date | Description |
|------------|------------|--|
| 80062505 | 2020-12-04 | Updated 1251163 to resolve FIR Follow-up, Elster GmbH ,Factory Contract #260586, FIR date Aug 3,2017 for certified HV Connector replacement. |
| 0002284426 | 2010-05-07 | Updated 1251163 to cover Potting Compound designation change and Vendor name change. |
| 0002038678 | 2008-07-04 | Updated 1251163 for constructional changes to Ignition Transformer. |

NOT UP TO DATE
www.docuhelp.com