

# Certificate



**No.: 968/FSP 2618.00/23**

<b>Product tested</b>	Flame Detector	<b>Certificate holder</b>	Honeywell International Inc. 2101 CityWest Blvd. TX 77042 Houston United States of America
-----------------------	----------------	---------------------------	---

<b>Type designation</b>	FDU 510 and FDU 520
-------------------------	---------------------

<b>Codes and standards</b>	EN 298:2022
----------------------------	-------------

<b>Intended application</b>	The Flame Detectors FDU 520 (permanent / continuous operation and FDU 510 (intermittent / non-permanent) fulfils the requirements according to EN 298.
-----------------------------	--

The product is designed for industrial and commercial gas-fired burner installations.

<b>Specific requirements</b>	The technical information and operating instructions have to be considered.
------------------------------	---

Valid until 2028-12-15

The issue of this certificate is based upon an evaluation in accordance with the Certification Program CERT FSP3 V2.0:2020 in its actual version, whose results are documented in Report No. 968/FSP 2618.00/23 dated 2023-12-14. This certificate is valid only for products, which are identical with the product tested. Issued by the certification body accredited by DAkkS according to DIN EN ISO/IEC 17065. The accreditation is only valid for the scope listed in the annex to the accreditation certificate D-ZE-11052-02-01.

**TÜV Rheinland Industrie Service GmbH**  
Bereich Automation  
Funktionale Sicherheit  
Am Grauen Stein, 51105 Köln

Köln, 2023-12-15

Certification Body Safety & Security for Automation & Grid

Dipl.-Ing. (FH) Wolf Rückwart