



EC TYPE-EXAMINATION CERTIFICATE

Number **E 001/01/1**

GASTEC NV, notified body **0063** hereby declares that

the **Multifunctional Controls**

series **LSV2**

made by **KROMSCHÖDER A.G.**

OSNABRÜCK, GERMANY,

complies with the essential requirements of the
Gas Appliances Directive (90/396/EEC).

The compliance is based on examination to:
EN 126 and prEN 1854

The products have been approved for:

Austria	Belgium	Germany
Denmark	Spain	Finland
France	United Kingdom	Greece
Ireland	Italy	Luxemburg
The Netherlands	Norway	Portugal
Sweden		

A description of the specific types, valid reports and
identification numbers is given in the appendices to this
certificate.

Apeldoorn, **1 May 1995**

A handwritten signature in blue ink, appearing to read "L. Noordzij".

dr. L. Noordzij,
president.

EC TYPE-EXAMINATION CERTIFICATE: E 001/01/1

Appendix no.: 1
 Dated: 1 May 1995
 P.I.N.: 92-0063-001-01
 Examination reports:
 119159 dated January 1995
 119341 dated May 1995

LSV2

Safety valve for laboratories, approved on EN 126;1995 and prEN 1854;1995, consisting of an automatic shut-off valve, a bypass valve and a pressure switch.

Shut-off valves class A
 Ambient temperature range: -15 - +60°C.
 Degree of protection IP 54.
 Mechanical strength group 2

TYPE NUMBER SURVEY:

LSV2	Type number
20, 25, 40	Connection sizes
R	Rp threaded connecting flanges
V	Rp threads with unions
01	Inlet pressure 100 mbar.
T	Working voltage: 220/240 V - 50/60 Hz.
M	Working voltage: 110 V - 50/60 Hz.
K	Working voltage: 24 V DC.
4	Switching point 4 mbar
12	Switching point 12 mbar