



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 1754568 (LR 112816)

Master Contract: 175131

Project: 2217656

Date Issued: 2009/10/21

Issued to: Elster GmbH

Postfach 2809
Osnabrueck, 49018
Germany
Attention: Stephen Mock

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Valdis Udris

Issued by: Valdis Udris

PRODUCTS

CLASS 3371 03 - VALVES (GAS) - Automatic - For Gas Appliances

CLASS 3371 83 - VALVES (GAS) - Automatic-For Gas Appliances-Certified to U.S. Standards

Model Number	Inlet Size	Outlet Size	PSIG
--------------	------------	-------------	------

·For Use With Natural, Liquefied Petroleum or Propane Gas

Automatic Safety Shut-off Valves

Trade Name: KROMSCHROEDER AG

VAS 1(T)10(N,R)/(N,L)(W,Q,K)	3/8"	3/8"	5
VAS 1(T)15(N,R)/(N,L)(W,Q,K)	1/2"	1/2"	5
VAS 1(T)20(N,R)/(N,L)(W,Q,K)	3/4"	3/4"	5
VAS 1(T)25(N,R)/(N,L)(W,Q,K)	1"	1"	5
VAS 2(T)25(N,R)/(N,L)(W,Q,K)	1"	1"	5



Certificate: 1754568 (LR 112816)

Master Contract: 175131

Project: 2217656

Date Issued: 2009/10/21

VAS 2(T)32(N,R)/(N,L)(W,Q,K)	1-1/4"	1-1/4"	5
VAS 2(T)40(N,R)/(N,L)(W,Q,K)	1-1/2"	1-1/2"	5
VAS 2(T)50(N,R)/(N,L)(W,Q,K)	2"	2"	5
VAS 3(T)40(N,R)/(N,L)(W,Q,K)	1-1/2"	1-1/2"	5
VAS 3(T)50(N,R)/(N,L)(W,Q,K)	2"	2"	5
VAS 3(T)65(N,R)/(N,L)(W,Q,K)	2-1/2"	2-1/2"	5

The above models are also certified for Commercial and Industrial Safety Shutoff Applications.

The above valves are certified with optional suffixes T, SL, SR, GL, GR.

The above valves are certified for operation at electrical ratings as follows:

VAS Series 230V ac, 50/60Hz, 29 to 54 VA holding.

Certified for operation in ambient temperatures -4°F to +140°F.

APPLICABLE REQUIREMENTS

ANSI Z21.21-2005-CSA 6.5-2005

Automatic Valves for Gas Appliances