

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E34649  
**Report Reference** E34649-20001103  
**Issue Date** 2020-MARCH-10

**Issued to:** HONEYWELL INTERNATIONAL INC  
ACS  
ENVIRONMENTAL & COMBUSTION CONTROLS  
1985 DOUGLAS DR N  
GOLDEN VALLEY, MN 55422-3935 USA

**This certificate confirms that  
representative samples of**

COMBUSTION-DETECTION EQUIPMENT FOR USE IN  
HAZARDOUS LOCATIONS  
USL, CNL Type C7012C, C7012F, C7024F, C7961F,  
C7061F2001, C7076D1027 combustion detectors for use in  
hazardous locations, Class I, Groups C and D, and Class II,  
Groups E, F, and G..

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

UL 1203 - Explosion-Proof, and Dust-Ignition-Proof  
Electrical Equipment for Use in Hazardous (Classified)  
Locations, CAN CSA C22.2 No. 30- M1986, Explosion-  
Proof Enclosures for Use in Class I Hazardous Locations,  
and CAN CSA C22.2 No. 25-1966, Enclosures for Use in  
Class II, Division 1, Groups E, F, and G Hazardous  
Locations.


**Additional Information:**

See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

