



Number	17GR0210/01	Replaces	17GR0210/00
Issue date	05-03-2024	Contract number	E0001
Due date	05-03-2034	Module	B (Type testing)
Report number	119262	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063BQ001/04		

EU TYPE EXAMINATION CERTIFICATE (GAR)

Kiwa hereby declares that the **flame supervision devices**, model(s):

S11T

Manufacturer

**Elster GmbH (Honeywell)
Strotheweg 1
49504 Lotte - Büren
Germany**

meet(s) the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard: EN 125: 2022

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Ron Scheepers
Managing director

CERTIFICATE

Kiwa Nederland B.V.
Wilmersdorf 50
P.O. Box 137
7300 AC APELDOORN
The Netherlands

<https://www.kiwaenergy.com>





Number	17GR0210/01	Replaces	17GR0210/00
Issue date	05-03-2024	Contract number	E0001
Due date	05-03-2034	Module	B (Type testing)
Report number	119262	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063BQ001/04	Page	1 of 1

APPENDIX TO EU TYPE EXAMINATION CERTIFICATE (GAR)

Manufacturer:
Elster GmbH (Honeywell)

List of all available types:
Thermo-electric flame supervision devices approved on EN125

Class A
Mechanical strength Group 2
Max. ambient temperature -20°C / 60°C

TYPE NUMBER SURVEY:

S11T Thermo-electric valve type S11T

15 Connection size DN 15
20 Connection size DN 20
25 Connection size DN 25

R Screw connections acc. ISO 7-1

01 Maximum inlet pressure 100 mbar
15 Maximum inlet pressure 1,5 bar

S optional switch

Remark: When the thermo-electrical valve is not provided with the optional switch, the letter 'S' is not listed in the type number survey