

EG-Baumusterprüfbescheinigung**EC type examination certificate****CE-0085BS0214**Produkt-Identnummer
product identification no.

Anwendungsbereich <i>field of application</i>	EG-Gasgeräte-richtlinie (90/396/EWG) <i>EC Gas Appliances Directive (90/396/EEC)</i>
Zertifikatinhaber <i>owner of certificate</i>	Elster GmbH Strotheweg 1, D-49504 Lotte (Büren)
Vertreiber <i>distributor</i>	Elster GmbH Strotheweg 1, D-49504 Lotte (Büren)
Produktart <i>product category</i>	accessories for gas appliances/pressure equipment: Tightness control (4115)
Produktbezeichnung <i>product description</i>	Tightness control
Modell <i>model</i>	LCU
Bestimmungsländer <i>countries of destination</i>	AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HU, IE, IS, IT, LT, LU, LV, MT, NL, NO, PL, PT, RO, SE, SI, SK
Prüfberichte <i>test reports</i>	type testing: 06/272/4115/958 from 25.07.2007 (EBI)
Prüfgrundlagen <i>basis of type examination</i>	EU/90/396/EWG (29.06.1990) DIN EN 1643 (01.02.2001) DIN EN 298 (01.01.2004) DIN EN 298-Ber/1 (01.09.2006)
Aktenzeichen <i>file number</i>	07-0402-GEE

16.11.2007, Rie A-1/2

Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle
date, issued by, sheet, head of certification bodyDVGW CERT GmbH - von der Deutschen Bundesregierung benannte und von der
Europäischen Kommission offiziell registrierte Stelle für die
Konformitätsbewertung von GasgerätenDVGW CERT GmbH - notified by the government of the Federal Republic of
Germany and officially registered by the European Commission for conformity
assessment of gas appliances**ZLS**

ZLS-ZE-527/07

DVGW CERT GmbH
Josef-Wirmer-Straße 1-3
53123 Bonn

Telefon: +49 228 91 88-888

Telefax: +49 228 91 88-993

eMail: info@dvgw-cert.com

Elektrische Daten: 230 V AC, 50 Hz, P = 20 VA, IP54
electrical data

Typ <i>type</i>	Technische Daten <i>technical data</i>	Bemerkungen <i>remarks</i>
LCU	ambient temperature range: 0...+60 °C	

Verwendungshinweise / Bemerkungen*hints of utilization / remarks*

protection class: I