



Number:	UKCA/0558/22/032	Replaces:	18GR0200/01
Issue Date:	07-02-2022	Contract Number:	PS7169
Due Date:	07-02-2032	Module:	B (Type Testing)
Report Number:	120052	Scope:	Gas Appliances
PIN:	0063AU1052	Page	1 of 2

UKCA TYPE EXAMINATION CERTIFICATE

Kiwa Ltd. hereby declares that the model type(s)

VE4..AA

Manufactured by Honeywell Product and Solutions Sarl
Rolle, Switzerland

Meet(s) the essential requirements as described in the:

Gas Appliances Regulation (Regulation (EU) 2016/426 as brought into GB law and amended), and the Gas Appliances (Enforcement) and Miscellaneous Amendment Regulations 2018 No 389, and amendments to UK SI 2019/696 Product Safety and Metrology, and subsequent amendments, The Product Safety, Metrology and Mutual Recognition Agreement (Amendment) (EU Exit) Regulations 2019 No 1246, and subsequent amendments. This certificate is not valid in Northern Ireland – and is applicable to England, Scotland and Wales only.

Reference standards: BS EN 161:2011+A3:2013

Signed on behalf of Kiwa Ltd.
(UK Approved Body Number 0558)

Mark Crowther
Technical Director
Kiwa Ltd.

39017601

CERTIFICATE

Kiwa Gastec
Kiwa House
Malvern View Business Park
Stella Way
Bishops Cleeve
Cheltenham
GL52 7DQ
United Kingdom
T +44 (0)1242 677877
F +44 (0)1242 676506
www.kiwa.co.uk



0217



Number:	UKCA/0558/22/032	Replaces:	18GR0200/01
Issue Date:	07-02-2022	Contract Number:	PS7169
Due Date:	07-02-2032	Module:	B (Type Testing)
Report Number:	120052	Scope:	Gas Appliances
PIN:	0063AU1052	Page	2 of 2

APPENDIX TO UKCA TYPE EXAMINATION CERTIFICATE

The Honeywell Technologies Sarl automatic shut-off valve(s), Series VE4..AA, are intended for use on gas burners, gas appliances and similar use.

List of all available types:

VE4..AA

Automatic shut-off valve approved on EN161

Class	: A
Mechanical group	: 2
Supply Voltage (Rp 3/8" .. 3/4")	: 230Vac / 50Hz : 110Vac / 50Hz
Supply voltage (Rp 1/4")	: 230 Vrac / 50Hz : 110 Vrac / 50Hz
Degree of protection	: IP65
Max. ambient temperature	: -150C / 600C
Max. inlet pressure	: 500mbar for Rp1/4" : 200mbar for Rp3/8" to Rp3/4"

Type survey:

VE. . . AA	: shut-off valve
. . 4. . . .	: line voltage
. . . 08. .	: connection Rp1/4 (brass body)
. . . 10. .	: connection Rp3/8 (aluminum body)
. . . 15. .	: connection Rp1/2 (aluminum body)
. . . 20. .	: connection Rp3/4 (aluminum body)