



|                |                  |                  |                  |
|----------------|------------------|------------------|------------------|
| Number:        | UKCA/0558/21/305 | Replaces:        | 17GR0209/00      |
| Issue Date:    | 06-12-2021       | Contract Number: | PS7133           |
| Due Date:      | 06-12-2031       | Module:          | B (Type Testing) |
| Report Number: | 120909           | Scope:           | Gas Appliances   |
| PIN:           | 0063BL1554       | Page             | 1 of 2           |

## UKCA TYPE EXAMINATION CERTIFICATE

Kiwa Ltd. hereby declares that the model type(s)

VGP

Manufactured by **Elster GmbH (Honeywell)**  
Lotte - Büren, Germany

Meet(s) the essential requirements as described in the:

**Gas Appliances Regulation (Regulation (EU) 2016/426 as brought into GB law and amended), and the Gas Appliances (Enforcement) and Miscellaneous Amendment Regulations 2018 No 389, and amendments to UK SI 2019/696 Product Safety and Metrology, and subsequent amendments, The Product Safety, Metrology and Mutual Recognition Agreement (Amendment) (EU Exit) Regulations 2019 No 1246, and subsequent amendments. This certificate is not valid in Northern Ireland – and is applicable to England, Scotland and Wales only.**

Reference standards: BS EN 161:2011+A3:2013

Signed on behalf of Kiwa Ltd.  
(UK Approved Body Number 0558)

Mark Crowther  
Technical Director  
Kiwa Ltd.

390/17601

# CERTIFICATE

**Kiwa Gastec**  
Kiwa House  
Malvern View Business Park  
Stella Way  
Bishops Cleeve  
Cheltenham  
GL52 7DQ  
United Kingdom  
T +44 (0)1242 677877  
F +44 (0)1242 676506  
[www.kiwa.co.uk](http://www.kiwa.co.uk)

# UK CA



0217



|                       |                  |                         |                  |
|-----------------------|------------------|-------------------------|------------------|
| <b>Number:</b>        | UKCA/0558/21/305 | <b>Replaces:</b>        | 17GR0209/00      |
| <b>Issue Date:</b>    | 06-12-2021       | <b>Contract Number:</b> | PS7133           |
| <b>Due Date:</b>      | 06-12-2031       | <b>Module:</b>          | B (Type Testing) |
| <b>Report Number:</b> | 120909           | <b>Scope:</b>           | Gas Appliances   |
| <b>PIN:</b>           | 0063BL1554       | <b>Page</b>             | 2 of 2           |

## APPENDIX TO UKCA TYPE EXAMINATION CERTIFICATE

### List of available types:

VGP

Electro-magnetic automatic shut-off valve approved on EN 161 Class A.

Degree of protection : IP 54  
Ambient temperature range : -20 to +60 °C.  
Mechanical strength : group 2

### Type number survey:

|             |  |
|-------------|--|
| VGP 10...25 | Connection size DN10, 25, 20 and 25  |
| R           | Screw connections acc. ISO 7   |
| 01          | Max. inlet pressure 150 mbar   |
| 02          | Max. inlet pressure 200 mbar   |
| W           | 230V, 50/60 Hz   |
| M           | 110V, 50/60 Hz   |
| Q           | 120V, 50/60 Hz   |
| 5           | Electrical connection Rectifier adapter without DIN plug (DIN43650, ISO4400)               |
| 6           | Electrical connection Rectifier adapter with DIN plug (DIN43650, ISO4400)                  |
| 6L          | Electrical connection Rectifier adapter with DIN plug (DIN43650, ISO4400) with signal lamp |
| 7           | Electrical connection Device socket, 3-pin, with rectifier circuit                         |
| V           | Viton valve disk seal  |
| Z           | Customer specified control   |

### Special conditions:

None